


DETAIL
NTS



GENERAL NOTES:

1. USE THIS INTERIM DWG UNTIL THE CITY OF ALBUQUERQUE'S PARK & RECREATION DEPARTMENT STD DWG IS AVAILABLE.
2. PVB'S UNAPPROVED FOR CONTAINMENT PROTECTION, EXCEPT FOR LAWN IRRIGATION SYSTEMS.
3. DO NOT INSTALL IN FLOOD PRONE AREAS.
4. DO NOT INSTALL PVB'S >5' ABOVE GROUND LEVEL.
5. PROTECT PVB'S FROM FREEZING W/ POSITIVE HEAT SOURCE.
6. HORIZONTAL INSTALLATION REQ'D, AS SHOWN.
7. JOINTS TO BE ADEQUATELY RESTRAINED.
8. METALIC RISER PIPING REQ'D.
9. CONSUMER MAY OBTAIN A PROCEDURE FOR WINTERIZING THE INSTALLATION FROM THE ADMINISTRATIVE AUTHORITY.

CONSTRUCTION NOTES:

- A. CURB STOP AND BOX.
- B. METER.
- C. SERVICE LINE, NO OUTLETS ALLOWED.
- D. SHUT-OFF VALVE, NORMALLY OPEN VALVE.
- E. UNIONS, MIN. 4" ABOVE GRADE.
- F. TEE W/ DRAIN PLUG OR BALL DRAIN VALVE, MIN. 6" ABOVE GRADE.
- G. APPROVED PVB, AS SHOWN.
- H. SPOOL, 12" MAX. LENGTH.
- I. ENCLOSURE. SEE WATER DWG 2389 FOR DESIGN CRITERIA.
- J. MASTER VALVE(ELECTRIC OR MANUAL), SEE LANDSCAPE DWG. 2703 FOR ELECTRIC VALVE DESIGN.
- K. 12" MIN. ABOVE ALL DOWNSTREAM PIPING & OUTLETS.
- L. SPRINKLER.

CITY OF ALBUQUERQUE

REVISIONS

12/90

LANDSCAPE
PRESSURE VACUUM
BREAKER
(PVB)

DWG. 2388B